



# **UPGRADE TIPS FOR RELAY MODULE**

#### Step 1:

Upgrade the Relay module as per the standard procedure

\*\*(Please Follow Manual step by step available on <a href="www.Smarthomebus.com">www.Smarthomebus.com</a> website)



Step 2:If the system still show the same problem kindly do the following:Unplug the 2 connecters of the Top Board and then connect them again + restart the unit.







# Step3:

Program the Relay Module as Needed Using Smart-Cloud Configurator \*\*(Smart-cloud is available on <a href="www.Smarthomebus.com">www.Smarthomebus.com</a> website)

And Test all channels programming and Usage with DDP and switches.

### Step 4:

Record the Address of Relay and All Channel Configuration in your Datasheet about the Project

## Step 5:

Make Backup of your Programming and save it in your Project Directory

### Step 6:

Disconnect the cables connecting to Top Board inside Relay Module and Leave them Disconnected (Disabling top Board as it was not available).



#### Step 7:

Close the Unit and Connect the loads as Normal, then test all to make sure all system is functioning Perfectly.

#### Congratulations

Now it will be good to go for many Years to come.

Thank you for your time .

Regards

Nahas Abdul

